



DISTRIBUTION MANIFOLD, 2" ISO LB. ABS (ACRYLONITRILE BUTADIENE-STYRENE). ALL TEES 90° 2"x2" BUSH TO REDUCE. MINIMUM PIPE SIZE FOR DISTRIBUTION 1/4".

4" STEEL OR POLY VINYL CHLORIDE WELL CASING. IF PITLESS ADAPTER CANNOT BE USED 20 GROUT SEAL OR APPROVED EQUIVALENT. (SUPPLY ENTRANCE)

NOTES:
 CHECK INSURANCE REGULATIONS FOR WATER STORAGE REQUIREMENTS.
 PROVIDE GROUNDED DOUBLE CONVENIENCE OUTLETS.
 WALLS AND ROOF OF BUILDING TO BE INSULATED IN LOCALITIES SUBJECT TO FREEZING TEMPERATURES.
 EQUIP WITH ADEQUATE LIGHTNING PROTECTION SYSTEM IN AREAS WHERE NEEDED.

SCALE: 3/8" = 1'-0" UNLESS OTHERWISE NOTED.

COOPERATIVE EXTENSION WORK IN AGRICULTURE AND HOME ECONOMICS
 DEPARTMENT OF AGRICULTURAL ENGINEERING
 UNIVERSITY OF MARYLAND
 UNITED STATES DEPARTMENT OF AGRICULTURE COOPERATING

FARMSTEAD WATER SUPPLY SYSTEM

USDA '63 EX. 5963 SHEET 1 OF 1